

Net-Metering Hosting Capacity
4th Quarter 2025

Distribution Transformer Name and/or Size (kVA)	Hosting Capacity (kWac)
10	3
15	4
25	7
37.5	10
50	14
75	20
100	27

This table represents the aggregate maximum allowable capacity of RE systems that can be integrated to ALECOs distribution system per transformer level.

This is only applicable for single-phase distribution transformers; other types will require transformer loading/or actual field measurements to assess the hosting capacity.

These limits ensure that the total installed capacity remains within the acceptable loading threshold of the distribution system.

The hosting capacity is only applicable within ALECO franchise area; for further technical information or clarification, please consult ALECO designated representatives.